



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-6th Floor
Schenectady, NY 12305
Purchasing@schenectadycounty.com
518.388.4240

RFB-2022-40
NISKAYUNA LIBRARY HVAC UPGRADES

ADDENDUM #2

Issued Date 3/29/2022

The purpose of this addendum is to provide detailed information to all Bidders. This addendum is hereby included in and made part of the Contract Documents, whether or not attached thereto. Receipt of this Addendum must be acknowledged on the bid form.

CONTENTS/RESPONSE TO QUESTIONS/REFERENCE TO ATTACHMENTS

Please acknowledge this addendum on your bid form.

Question 1: What is to be done with the projector and smoke heads in the ceiling that is being demo'd?

Answer 1: All fixtures in the ceiling to be temporarily supported from the structure above for the ceiling grid to be removed and replaced.

Question 2: What are the specifications of the new equipment being installed?

Answer 2: See attached cut sheets and drawings for purchased equipment.

NOTE: EQUIPMENT HAS CHANGED FROM ORIGINAL DRAWING REVISION. PLEASE REFERENCE ADDENDA 1 AND INFORMATION BELOW.

Changes to M001 in Addition to Information provided in Addenda #1:

Heating Coil Purchased by County for Contractor Installation:

Qty. 1

TAG: HTCL-1

Coil for use in MCC Unit (MCCA)

Left Hand Supply

2 Rows

35" (889 mm) coil height

59" (1499 mm) finned length

Aluminum Fins

END OF ADDENDUM #2



Schenectady County Office of Facilities
NISKAYUNA HVAC REPLACEMENT
RFB-2022-40
Pre-Bid Walk Through

Name:	Company:	Phone:	Email:
Jim Bernard	WILKINS MECHANICAL	607 760 7070	Jim@wilkinsmechanical.net
Chris Nobile	M/E	518-671-5641	Cdnobile@newsday.com
Erin Reich	Schidy County	518 888 4298	Purchasing@Schenectady
Scott Tomlinson	Schidy County	518 388 4298	County.com