



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-2nd Floor
Schenectady, NY 12305
Purchasing@schenectadycounty.com
518.388.4240

RFB-2022-49
SCCC OUTDOOR EMERGENCY PHONE SYSTEM

ADDENDUM #1

Issued Date 12/1/22

The purpose of this addendum is to provide detailed information to all Bidders. This addendum is hereby included in and made part of the Contract Documents, whether or not attached thereto. Receipt of this Addendum must be acknowledged on the bid form.

CONTENTS/RESPONSE TO QUESTIONS/REFERENCE TO ATTACHMENTS

Please acknowledge this addendum on your bid form.

1) Is there currently wiring to the devices? If so, what type is it?

Existing Units that are specified for replacement are wired with 120VAC and have analog copper phone lines.

END OF ADDENDUM #1



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-2nd Floor
Schenectady, NY 12305
Purchasing@schenectadycounty.com
518.388.4240