



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-2nd Floor
Schenectady, NY 12305
Purchasing@schenectadycounty.com
518.388.4240

RFB-2023-49
NORTH SIDE OF ALPLAUS SIDEWALK CONSTRUCTION

ADDENDUM # 3

06/13/2023

The purpose of this addendum is to provide detailed information to all Bidders. This addendum is hereby included in and made part of the Contract Documents, whether or not attached thereto. Receipt of this Addendum must be acknowledged on the bid form.

The following documents is hereby included in the documents posted on Bidnet and provided to plan holders:

Question 1:

Item 608.94010007 IMPRINTING AND COLORING OF ASPHALT CONCRETE PAVEMENT consists of reheating and printing the asphalt, then applying 3-4 coats of Streetbond coatings. This is generally used in low-traffic or non-traffic areas due coatings prematurely wearing from high traffic areas.

Item 601.04000024 AGGREGATE REINFORCED THERMOPLASTIC PAVEMENT SURFACE TREATMENT has been and is currently being specified for crosswalks within Schenectady and NYSDOT. However, the areas where it is to be installed are generally specified for new asphalt installation. If the areas were paved within the last 2 years there's the possibility that new asphalt wouldn't be required to install the thermoplastic.

Answer 1:

Bidders should bid the plans as they are and then the County, the engineer and the contractor can talk about the desired outcome.

Please acknowledge this addendum on your bid form.

END OF ADDENDUM #3