



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-2nd Floor
Schenectady, NY 12305
Purchasing@schenectadycountyny.gov
518.388.4240

RFB-2023-54
SCHENECTADY COUNTY RAY WEMPLE MEMORIAL RINK ADDITIONS AND
RENOVATIONS

ADDENDUM #1

Date: 12/04/2023

The purpose of this addendum is to provide detailed information to all Bidders. This addendum is hereby included in and made part of the Contract Documents, whether or not attached thereto. Receipt of this Addendum must be acknowledged on the bid form.

The following documents is hereby included in the documents posted on Bidnet and provided to plan holders:

CONTENTS/ RESPONSE TO QUESTIONS/ REFERENCE TO ATTACHMENTS

Additional Pre-Bid Walkthrough Date & Time: Wednesday December 6th, 2023 @ 9:00am.
This is for those who missed the first pre-bid meeting on 11/30/23.

General Information:

The mandatory pre-bid walkthrough requirement is being waived to allow those who missed the initial walkthrough to bid on this project.

Questions:

Question 1: The specs says "Schedule is based on Alternates". Is there a rough start date & completion date?

Answer: Beginning of March to end of December TENTATIVE.

Question 2: Can 4" ductile iron pipe be used in place of 3" copper for the new water service?

Answer: We prefer copper.

Please acknowledge this addendum on your bid form.

END OF ADDENDUM #1