



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-2nd Floor
Schenectady, NY 12305
purchasing@schenectadycountyny.gov
518.388.4240

RFB-2024-47
SUNY SCCC ELSTON HALL SKYLIGHTS AND WINDOW FAÇADES REPLACEMENT
C2 DESIGN GROUP

ADDENDUM #2

Issued Date: 07/25/2024

The purpose of this addendum is to provide detailed information to all Bidders. This addendum is hereby included in and made part of the Contract Documents, whether or not attached thereto. Receipt of this Addendum must be acknowledged on the bid form.

CONTENTS/RESPONSE TO QUESTIONS/REFERENCE TO ATTACHMENTS

General:

1. This addendum answers questions for Bid #RFB-2024-47.

Contractor request for information:

1. Please issue project design loads, especially flat roof snow load, snow drift load (if applicable) and design wind load.
 - a. Response: The flat roof snow load is 30.8 psf and the design wind speed would be 110 mph. Due to the distance of the skylight from the perimeter surrounding building walls and roof steps, the Skylight would not be directly impacted by the drifted snow.

Please acknowledge this addendum on your bid form.

END OF ADDENDUM #2