



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-2nd Floor
Schenectady, NY 12305
purchasing@schenectadycountyny.gov
518.388.4240

RFB-2024-49
NEW FUSELAGE CONCRETE TRAINER PAD AT THE SCHENECTADY COUNTY
AIRPORT

ADDENDUM #3

Date: 07/22/2024

The purpose of this addendum is to provide detailed information to all Bidders. This addendum is hereby included in and made part of the Contract Documents, whether or not attached thereto. Receipt of this Addendum must be acknowledged on the bid form.

The following documents is hereby included in the documents posted on Bidnet and provided to plan holders:

CONTENTS/ RESPONSE TO QUESTIONS/ REFERENCE TO ATTACHMENTS

General RFI's:

1. **Question 1: Will the contractor have to cover the cost of inspection and testing?**
 - a. **The County will be paying for the inspection and testing agency. They will be approving all rebar and grounding prior to the pour and then taking cylinders and infield concrete testing.**

2. **Question 2: What finish should the concrete have?**
 - a. **The concrete will have a broomed finish.**

Please acknowledge this addendum on your bid form.

END OF ADDENDUM #3

RFB 2024-49 Concrete Trainer Pad at SC Airport Job Walk #2

07/19/2024 2:00PM EST

Name	Company	Phone Number	Email
Peter Knutson	Schenectady County	518-356-5340	Peter.Knutson@schenectadycountyny.gov
<i>MICHAEL ANGELOZZI</i>	<i>ANGELOZZI MASONRY</i>	<i>(518) 878-1018</i>	<i>Angelozzi.masonry@gmail.com</i>
<i>Rene Pedroso</i>	<i>Keller Construction</i>	<i>518-852-6901</i>	<i>vpedroso@wjkeller.com</i>